

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20211209-R40681  
**Report Reference** R40681  
**Issue Date** 2021-December-09

**Issued to:** ARMACELL GMBH  
ROBERT-BOSCH-STRASSE 10  
MUENSTER, 48153 Germany

**This certificate confirms that  
representative samples of**

Firestop Devices  
ArmaProtect CT / CT ML

ArmaProtect CT Firestop Device for use in Through-Penetration Firestop System Nos. C-AJ-1754, C-AJ-2931, F-A-3084, F-A-8066, W-J-1335, W-J-3276, W-J-8098, W-J-8099, W-L-1606, W-L-3480, W-L-8139.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**  
**Additional Information:**

ANSI/UL 1479, "Fire Tests of Penetration Firestops."  
See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

